

**City of Ottawa
Combined Sewer Overflow (CSO)
Locations and Minimum Amount of
Rainfall Required to Cause
Potential Overflow**

CSO	Minimum Rainfall for Potential Overflow
009	0.15"
011	0.15"
018A	0.15"
007	0.25"
006	0.50"
013	0.50"
014	0.50"
018B	0.50"
004	0.75"
019	> 1.0"

